



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from A.P.V. Education Centre, Pandu Nagar, Kanpur

Name & designation of the person collecting samples ALKA SINGH - CHEMIST

D.No. 380/SPA/Chem 09/6/2025

Date & time of collection	Source of sample	Colony count on Agar Agar per M. L. of water		Presumptive Coliform count				Probable on of coliform organism in 100 CC of original water	Free Residual Chlorine part per Million	REMARKS
		at 37.c in 48 hours	at room temp- rature in 72 hours	Quantity of water put in each tube No of tubes put up	50ML 1	10 ML 5	1 ML 5			
05/6/2025	'SUBMERSIBLE'	'39'	'86'	—	NIL	'2'	'1'	'ZERO'	NIL	'Satisfactory'


Remark: Chlorination is very necessary / F.R.C. must be 0.2 ppm.

Copy for Information Forwarded to

(1) ^{upt} A.P.V. Education Centre, Pandu Nagar, Kanpur

(2) N.S.A. Kanpur Nagar Nigam.


Manager
A.P.V. Education Centre
Pandu Nagar, Kanpur


Principal
A.P.V. Education Centre
Pandu Nagar, Kanpur


Nagar Swasthya Adhikari
नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर
ALKA SINGH
(Chemist)
Nagar Nigam Kanpur